

## #2000 Snow Guard Specification Sheet

### PART 1 - GENERAL

#### 1.1 SUMMARY

##### A. WORK INCLUDES

1. #2000 Snow guard that does not penetrate the roof using S-5! Technology.
2. Provide appropriate snow guard and fasteners for the roof system.

##### B. RELATED SECTIONS

1. Section 07600: Flashing and Sheet Metal. MasterFormat™ 2004 07 60 00
2. Section 07610: Metal Roofing MasterFormat™ 2004 07 61 00
3. Division 7: Thermal and Moisture Protection.

#### 1.2 SYSTEM DESCRIPTION

##### A. COMPONENTS:

1. #2000 Snow guard system consists of snow guard block and flag assembly and set screws.
2. Aluminum tubing.
3. Couplings.
4. End Plugs (optional).
5. Ice Flags (optional).
6. End Collars (optional).

##### B. DESIGN REQUIREMENTS:

1. Spacing to be recommended by manufacturer or building engineer.
2. Uses 2 set screws per snow guard.
3. It is important to design new structures or assess existing structures to make sure that they can withstand retained snow loads.

#### 1.3 SUBMITTAL

- A. Submit manufacturer's specifications, standard detail drawings, recommended layout and installation instructions.

#### 1.4 QUALITY ASSURANCE

- A. Installer to be experienced in the installation of specified roofing material and snow guards for not less than 5 years in the area of the project.

#### 1.5 DELIVERY / STORAGE / HANDLING

- A. Inspect material upon delivery and order replacements for any missing or defective items. Keep material dry, covered and off the ground until installed.

### PART 2 - PRODUCTS

#### 2.1 MANUFACTURER

- A. Alpine SnowGuards. A division of Vermont Slate & Copper Services Inc., 289 Harrell St, Morrisville, VT (888) 766-4273, www.alpinesnowguards.com.

---

## #2000 One-Pipe Clamp to the Seam Snow Guard for Standing Seam Metal Roofs

## **2.2 MATERIALS**

- A. Snow guard Block and Flag are extruded and milled 6061-T6 and 6005-T5 Aluminum
- B. Tubing is 6061-T6 1" outside diameter and 1/8" wall thickness extruded Aluminum.
- C. Couplings 2011 Aluminum 3" long.
- D. End Caps are 302 stainless steel.
- E. End Collars are 6061-T6 aluminum shaft collars.
- F. Bolts are 302 or 304 Stainless Steel.
- G. Set screws: 300 Series stainless steel, 18-8 alloy, 3/8 inch diameter, with round nose point, two per clamp. Cup-point setscrews are not permitted.

## **2.3 FINISH**

- A. All materials provided mill finish. Coatings available upon request.

## **PART 3 - EXECUTION**

### **3.1 EXAMINATION**

- A. Substrate: Inspect roof system to be properly attached and installed to withstand additional loading incurred. Notify General Contractor of any deficiencies before installing Alpine SnowGuards.

### **3.2 INSTALLATION**

- A. Comply with architectural drawings for location and with Manufacturer's instructions for installation

---

## **#2000 One-Pipe Clamp to the Seam Snow Guard for Standing Seam Metal Roofs**