



ALPINE SNOWGUARDS

A Division of Vermont Slate & Copper Services, Inc.

Following numbers are based on test data from the pipe style snowguards test done by Vermont Testing on July 25, 1996.

The following numbers are for a 2-pipe system.

Bracket Spacing	Load per Foot	Load at which pipes start to fail
48"	320	1280
36"	773	2319
30"	1344	3360
24"	1480	2960

Fasteners holding the brackets to the decking must exceed the "Total Load on Bracket" for the system to be properly designed.