

PD80 (All Models) Snow Guard Specification Sheet

Snow Guards

PART 1 – GENERAL

1.1 SUMMARY

A. WORK INCLUDES

1. PD80 Snow guard that attaches directly to the roof deck.
2. Coordinate with the installation of the roof to assure proper placement of the snow guards.
3. Provide appropriate snow guard and fasteners for the roof system

B. RELATED SECTIONS

1. Section 0772 00:Roof Accessories MasterFormat™ 2004 07 72 00
2. Section 07600: Flashing and Sheet Metal MasterFormat™ 2004 07 60 00
3. Section 07610: Metal Roofing MasterFormat™ 2004 07 61 00
4. Division 7: Thermal and Moisture Protection.

1.2 SYSTEM DESCRIPTION

A. COMPONENTS:

1. PD80 Snow guard system consists of individual metal snow guard made from aluminum or steel.
2. Fasteners
 - a. All PD80 snow guards should be fastened using screws or welding techniques.
 - b. To be of metal compatible with snow guards.
 - c. Fasteners should be selected for compatibility with the roof deck.
 - d. Fastener strength should exceed or be equal to that of the snow guard system.

B. DESIGN REQUIREMENTS:

1. Spacing to be recommended by manufacturer or building engineer.
2. Minimum 2 fasteners per snow guard.
3. It is important to design new structures or assess existing structures to make sure that they can withstand retained snow loads.



1.3 SUBMITTAL

- A. Submit manufacturer's specifications, standard detail drawings, installation instructions, and recommended layout.

1.4 QUALITY ASSURANCE

- A. Installer to be experienced in the installation of specified roofing material and snow guards for not less than 5 years in the area of the project.

1.5 DELIVERY / STORAGE / HANDLING

- A. Inspect material upon delivery and order replacements for any missing or defective items. Keep material dry, covered and off the ground until installed.

PART 2 – PRODUCTS

2.1 MANUFACTURER

- A. Alpine SnowGuards. A division of Vermont Slate & Copper Services Inc.
289 Harrel St. Morrisville, VT 05661, (888) 766-4273
www.alpinesnowguards.com.

2.2 MATERIALS

- A. 6063-T52 Aluminum with 0.083 wall thickness.
- B. 1010 or 1008 Mild Steel with 0.083 wall thickness.

2.3 FINISH (choose one):

- A. Mill Finish – standard
- B. Powder Coated – available at additional cost





PART 3 – EXECUTION

3.1 EXAMINATION

A. Substrate

1. Inspect structure on which snow guard system is to be installed and verify that it will withstand any additional loading that it may incur. Notify general contractor of any deficiencies before installing Alpine SnowGuards.
2. Verify that roofing material has been installed correctly prior to installing snow guards.

3.2 INSTALLATION

- #### **A. Comply with architectural drawings and snow guard manufacturer's recommendations for location of system. Comply with manufacturer's written installation instructions for installation and layout.**

Document Version 04.28.2015
07 72 53 Snow Guards

