



ASG4000G (U&T) Snow Guard Specification Sheet

Snow Guards

PART 1 – GENERAL

1.1 SUMMARY

A. WORK INCLUDES

1. ASG4000G Snow guard that does not penetrate the roof using clamp to seam.
2. Coordinate with the installation of the roof to assure proper placement of the snow guards.
3. Provide appropriate snow guard and fasteners for the roof system

B. RELATED SECTIONS

1. Section 07600: Flashing and Sheet Metal. MasterFormat™ 2004 07 60 00
2. Section 07310: Shingles MasterFormat™ 2004 07 31 00
3. Section 07320: Roofing Tiles MasterFormat™ 2004 07 32 00
4. Division 7: Thermal and Moisture Protection.

1.2 SYSTEM DESCRIPTION

A. COMPONENTS:

1. ASG4000G Snow guard system consists of snow guard block, bracket assembly and (3) set screws.
2. Tubing (Snow Fence).
3. Couplings.
4. End Caps.
5. End Collars.
6. Ice Flags.

B. DESIGN REQUIREMENTS:

1. Spacing to be recommended by manufacturer or building engineer.
2. Install a minimum of (3) set screws per snow guard.
3. It is important to design new structures or assess existing structures to make sure that they can withstand retained snow loads.



1.3 SUBMITTAL

- A. Submit manufacturer's specifications, standard detail drawings, installation instructions, and recommended layout.

1.4 QUALITY ASSURANCE

- A. Installer to be experienced in the installation of specified roofing material and snow guards for not less than 5 years in the area of the project.

1.5 DELIVERY / STORAGE / HANDLING

- A. Inspect material upon delivery and order replacements for any missing or defective items. Keep material dry, covered and off the ground until installed.

PART 2 – PRODUCTS

2.1 MANUFACTURER

- A. Alpine SnowGuards. A division of Vermont Slate & Copper Services Inc.
289 Harrel St. Morrisville, VT 05661, (888) 766-4273
www.alpinesnowguards.com.

2.2 MATERIALS

- A. Snow Guard Block and Bracket - 6000 Series Aluminum.
- B. Tubing (choose one):
 - 1. Aluminum – 6000 Series, 1” outside diameter and .120” wall thickness, extruded.
 - 2. Stainless Steel – 304 alloy, same dimensions as aluminum, welded.
- C. Couplings (choose one):
 - 1. Aluminum – 6000 Series
 - a. Internal and concealed coupling 3” long.
 - b. External and exposed coupling which can also serve as an expansion mechanism 5” long.



2. Stainless Steel – 304 Series

- a. Internal and concealed coupling 3” long.
- b. External and exposed coupling which can also serve as an expansion mechanism 5” long.

D. End Caps - 304 Stainless Steel.

E. End Collars (choose one):

- a. 6000 Series Aluminum.
- b. 304 Stainless Steel.

F. Ice Flags (choose one):

- a. 6000 Series Aluminum 3” wide x length (as needed)
- b. 304 Stainless Steel.

2.3 FINISH (choose one):

- A. Mill Finish – standard
- B. Powder Coated – available at additional cost

PART 3 – EXECUTION

3.1 EXAMINATION

A. Substrate

1. Inspect structure on which snow guard system is to be installed and verify that it will withstand any additional loading that it may incur. Notify general contractor of any deficiencies before installing Alpine SnowGuards.
2. Verify that roofing material has been installed correctly prior to installing snow guards.

3.2 INSTALLATION

- A. Comply with architectural drawings and snow guard manufacturer’s recommendations for location of system. Comply with manufacturer's written installation instructions for installation and layout.

Document Version 04.28.2015
07 72 53 Snow Guards

